OWNER'S MANUAL

Ceiling And Floor Type

DOOR UNIT INDOOR UNIT Air flow louver (at air outlet) Air inlet (with air filter in it) Installation part Oisplay panel 6 Remote controller 6 Drain pipe NOTE

All the pictures in this manual are for explanation purpose only. They may be slightly different from the air conditioner you purchased(depend on model). The actual shape shall prevail.

A wet cloth may be used to clean the indoor unit if it is

Never use a damp cloth on the remote controller.

verv dirtv.

Do not use a chemically-treted duster for wiping or leave such material on the unit for long. it may damage or fade the surface of the unit.

Do not use benzine, thinner, polishing powder, or similar solvents for cleaning. These may cause the plastic surface to crack or deform.

Maintenance after a long stop period

(eg. at the beginning of the season) Check and remove everything that might be blocking inlet and outlet vents of indoor units and outdoor units.

Clean air filters and casings of indoor units. Refer to "Cleaning the air filter" for details on how to proceed and make sure to install cleaned air filters back in the same position.

Turn on the power at least 12 hours before operating the unit in order to ensure smoother operation. As soon as he power is turned on, the remote controller displays appear.

Maintenance before a long stop period

(eg. at the end of the season) Let the indoor units run in fan only operation for about half a day in order to dry the interior of the units.

Clean air filters and casings of indoor units. Refer to " Cleaning the air filter" for details on how to proceed and make sure to install cleaned air filters back in the same

Cleaning the air filter

position.

The air filter can prevent the dust or other particulate from going inside. In case of blockage of the filter, the working efficiency of the air conditioner may greatly decrease. Therefore, the filter must be cleaned once two weeks during long time usage.

If the air conditioner is installed in a dust place, clean the the air filter frequent.

If the accumulated dust is too heavy to be cleaned, please replace the filter with a new one(replaceable air filter is an optional fitting).

1 3.2-10.5KW

- Open the air intake with the screwdriver or something like that (Refer to Fig.6-1)
- Take out the air filter. (Refer to Fig. 6-2)
- dry it in cool place.
- Re-install the air filter in the reverse order of Fig.6-2.

2 14-16KW

- Directly pull out the air filter from air inlet as indicated in
- Clean the air cleaning filter with water or vacuum cleaner,
- then dry it in cool place.
- Re-install the air filter in the reverse order of Fig.6-3.


• The air-in side should face down when using water. CAUTION Do not dry out the air filter under direct sunshine or with fire.

Thank you very much for purchasing our air conditioner,

NOTE

• The air-in side should face up when using vacuum cleaner.

Before using your air conditioner, please read this manual carefully and keep it for future reference.



7. FOLLOWING SYMPTOMS ARE NOT AIR CONDITIONER TROUBLES

Symptom 1: The system does not operate

- Clean the air cleaning filter with water or vacuum cleaer, then
 The air conditioner does not start immediately after the ON/OFF button on the romote controller is pressed. If the operation lamp lights, the system is in normal condition. To prevent overloading of the compressor motor, the air conditioner starts 3 minutes after it is turned ON.
 - If the operation lamp and the "PRE-DEF indicator(cooling and heating type) or fan only indicator(cooling only type)" light, it means you choose the heating model. When just starting, if the compressor has not started, the indoor unit appears "anti cold wind" protection because of its overlow outlet temperature.

Symptom 2: Change into the fan mode during 8. TROUBLESHOOTING

- In order to prevent the indoor evaporator frosting, the system will change into fan mode automatically, restore to the cooling mode after soon.
- When the room temperature drops to the set temperature, the compressor goes off and the indoor unit changes to fan mode; when the temperature rises up, the compressor starts again. It is same in the heating mode.

Symptom 3: White mist comes out of a unit

Symptom 3.1: Indoor unit

- When humidity is high during cooling operation If the interior of an indoor unit is extremely contaminated, the temperature distribution inside a room becomes uneven. It is necessary to clean the interior of the indoor unit. Ask your dealer for details Water leaks from indoor unit. on cleaning the unit. This operation requires a qualified service erson
- Symptom 3.2: Indoor unit, outdoor unit

Symptom 4.1: Indoor unit

steam and is exhausted.

Sptom 4: Noise of air conditionerscooling

- A continuous low "shah" sound is heard when the system is in cooling operation or at a stop. When the drain pump (optional accessories) is in operation, this noise is heard.
- A "pishi-pishi" squeaking sound is heard when the system stops after heating operation. Expansion and contraction of plastic parts caused by temperature change make this noise.

Symptom 4.2: Indoor unit, outdoor unit

- A continuous low hissing sound is heard when the system is in This is the sound of refrigerant gas flowing through both indoor
- A hissing sound which is heard at the start or immediately after stopping operation or defrost operation. This is the noise of refrigerant caused by flow stop or flow

Symptom 4.3: Outdoor unit

and outdoor units.

- When the tone of operating noise changes. This noise is caused by the change of frequency.
- Symptom 5: Dust comes out of the unit
- When the unit is used for the first time in a long time.

This is because dust has gotten into the unit.


- Symptom 6: The units can give off odours
- The unit can absorb the smell of rooms, furniture, cigarettes, etc., and then emit it again.

Symptom 7: The outdoor unit fan does not

During operation. The speed of the fan is controlled in order to optimize product operation.

owner's manual

owner's manual



Troubles and causes of air conditioner 8.1

If one of the following malfunctions occur, stop operation, shut off the power, and contact with your dealer.

- The operation lamp is flashing rapidly (5Hz) This lamp is still flashing rapidly after turn off the power and turn on again. (See in Table 8-1a and Table 8-1b)
- Remote controller receives malfunction or the button does not
- A safety device such as a fuse, a breaker frequently actuates.
- Obstacles and water enter the unit.

- Other malfunctions.

work well.

If the system does not properly operate except the above When the system is changed over to heating operation after mentioned cases or the above mentioned malfunctions is defrost operation Moisture generated by defrost becomes evident, investigate the system according to the following procedures. (See in Table 8-2)

> 8.2 Troubles and causes of remote controller Before asking for serving or repairing, check the following points.(See in Table 8-3)

IMPORTANT SAFETY INFORMATION1 TEMPORARY OPERATIONS	ſ	CONTENTS
AIR CONDITIONER OPERATIONS AND PERFORMANCE		TEMPORARY OPERATIONS 2 AIR CONDITIONER OPERATIONS AND PERFORMANCE 3 HINTS FOR ECONOMICAL OPERATION 4 ADJUSTING AIR FLOW DIRECTION 4 MAINTENANCE 4 FOLLOWING SYMPTOMS ARE NOT AIR CONDITIONER 5

IMPORTANT SAFETY INFORMATION

To prevent injury to the user or other people and property damage, the following instructions must be followed. Incorrect operation due to ignoring of instructions may cause harm or

The safety precautions listed are divided into two categories. In either case, important safety information is listed which must be read.

WARNING
Failure to observe a warning may result in death. The appliance shall be installed in accordance with national wiring regulations.

CAUTION _ _ _ _ _ _ _ _ to the equipment.

WARNING

Ask your dealer for installation of the air conditioner. Incomplete installation performed by yourself may result in a water leakage, electric shock, and fire.

Ask your dealer for improvement, repair, maintenance. Incomplete improvement, repair, and maintenance may result

in a water leakage, electric shock, and fire.

In order to avoid electric shock, fire or injury, or if you detect any abnormality such as smell of fire, turn off the power supply and call your dealer for instructions.

Never let the indoor unit or the remote controller get wet. It may cause an electric shock or a fire.

Never press the button of the remote controller with a hard, pointed object. The remote controller may be damaged.

Never replace a fuse with that of wrong rated current or other wires when a fuse blows out. Use of wire or copper wire may cause the unit to break down or cause a fire.

It is not good for your health to expose your body to the air flow for a long time.

Do not insert fingers, rods or other objects into the air inlet or outlet. When the fan is rotating at high speed, it will cause injury.

Never use a flammable spray such as hair spray, lacquer or paint near the unit. It may cause a fire.

Never touch the air outlet or the horizontal blades while the swing flap is in operation. Fingers may become caught or the unit may break down.

Never put any objects into the air inlet or outlet. Objects touching the fan at high speed can be dangerous.

Never inspect or service the unit by yourself. Ask a qualified service person to perform this work.

Do not dispose this product as unsorted municipal waste. Collection of such waste separately for special treatment is necessary.

Do not dispose of electrical appliances as unsorted municipal waste, use separate collection facilities. Contact you local government for information regarding the connection systems available.

If electrical appliances are disposed of in landfills or dumps, hazardous substances can leak into the groundeater and get into the food chain, damaging your health and well-being.

To prevent refrigerant leak, contact your dealer. When the system is installed and runs in a small room, it is required to keep the concentration of the refrigerant, if by any chance coming out, below the limit. Otherwise, oxygen in the room may be affected, resulting in a serious accident.

The refrigerant in the air conditioner is safe and normally does not leak. If the refrigerant leaks in the room, contact with a fire of a burner, a heater or a cooker may result in a harmful gas.

Turn off any combustible heating devices, ventilate the room, and contact the dealer where you purchased the

Do not use the air conditioner until a service person confirms that the portion where the refrigerant leaks is repaired.



Do not use the air conditioner for other purposes. In order to avoid any quality deterioration, do not use the unit for cooling precision instruments, food, plants, animals or works of art.

Before cleaning, be sure to stop the operation, turn the breaker off or pull out the supply cord. Otherwise, an electric shock and injury may result.

In order to avoid electric shock or fire, make sure that an earth leak detector is installed.

Be sure the air conditioner is grounded. In order to avoid electric shock, make sure that the unit is grounded and that the earth wire is not connected to gas or water pipe, lightning conductor or telephone earth wire.

In order to avoid injury, do not remove the fan guard of the outdoor unit.

owner's manual

able 8-1a

NO.	MALFUNCTION & PROTECTION DEFINE	LED 1 OPERATION	LED2 TIMER	LED3 DEF.FAN	LED4 ALARM	DISPLAY DIGITAL TUBE	
1	Indoor fan motor speed out of control			\bigcirc	\bigcirc	E8	
2	In-Outdoor unitCOMM. Checking channel is abnormal		\bigcirc			E1	
3	R oom TEMP. sensor checking channel is abnormal	\bigcirc				E2	
4	Pipe TEMP. Sensor checking channel isabnormal(T2)	\bigcirc				E3	
5	Pipe TEMP. Sensor checking channel isabnormal(T2B)	\bigcirc				E4	
6	EPPR OM malfunction			\bigcirc		E7	
7	Water-level alarm malfunction				\bigcirc	EE	
8	Outdoor malfunction				\bigcirc	Ed	
9	Indoor twins communication malfunction		\bigcirc		\bigcirc	F3	
10	Other malfunction of twins	\bigcirc			\bigcirc	F4	
11	Refrigerant leakage detection malfunction			\bigcirc	\bigcirc	EC	
Light Flashing at 2.5HZ Flashing at 0.5HZ							

Applicable to inverter air conditioner only

;	8-1b	 _	

NO.	MALFUNCTION & PROTECTION DEFINE	LED1 OPERATION	LED2 TIMER	LED3 DEF.FAN	LED4 ALARM	DISPLAY DIGITAL TUBE
•	In-Outdoor unit COMM. Checking channel is abnormal	\bigcirc		\bigcirc		E1
•	Room temperature sensor checking channel is abnormal		\bigcirc			E2
•	Pipe temperature sensor checking channel is abnormal	\bigcirc				E3
•	Outdoor TEMP. sensor checking channel is abnormal			\bigcirc		E4
•	Outdoor malfunction	\bigcirc	\bigcirc	\bigcirc	\bigcirc	E6
•	Pump temperature sensor malfunction				\bigcirc	E5
•	EEPROM malfunction	\bigcirc	\bigcirc			E7
•	Water-level alarm malfunction				\bigcirc	E8
•	Refrigerant leakage detection malfunction	\bigcirc			\bigcirc	EC
•	DC motor speed out of control		\bigcirc		\bigcirc	Eb
•	Outdoor unit low pressure error	\bigcirc	\bigcirc	\bigcirc		Ed
	💿 Light 🔘 Fla	shing at 5HZ		Flashing	at1HZ	

Applicable to fixed-frequency air conditioner only

Do not operate the air conditioner with a wet hand. An electric shock may happen.

Do not touch the heat exchanger fins. These fins are sharp and could result in cutting injuries

Do not place items which might be damaged by moisture under the indoor unit. Condensation may form if the humidity is above 80%, the If the supply cord is damaged, it must be replaced by the

manufacturer, its service agent or similarly qualified

Do not operate your air conditioner in a wet room such

persons in order to avoid a hazard.

as a bathroom or laundry room.

TEMPORARY OPERATIONS

Function indicators on indoor unit display panel

The air conditioner consists of the indoor unit, the outdoor unit,

(P)

DEF./FAN ALARM

NOTE:DEF indicator(cooling and heating type)

Alarm indicator Temporary button

Display panel

PRE-DEF indicator(cooling and heating

or fan only indicator(cooling only type)

Fig. 2-2

Alarm indicator Infrared signal receiver

Display panel Fig. 2-3

PRE-DEF indicator(cooling and heating

or fan only indicator(cooling only type)

Temperature indecator

or FAN indicator(cooling only type)

Display panel Fig. 2-1

the connecting pipe and the remote controller. (See Fig.1)

MANUAL OPERATION TIMER

 Θ

 \bigcirc

 \odot

Infrared signal receiver

Timer indicator

Infrared signal receiver

Operation lamp

Operation lamp

Timer indicator

drain outlet is blocked or the filter is polluted. After a long use, check the unit stand and fitting for damage

If damaged, the unit may fall and result in injury.

with the air conditioner.

unit due to the heat.

To avoid oxygen deficiency, ventilate the room sufficiently if equipment with burner is used together

Arrange the drain hose to ensure smooth drainage. Incomplete drainage may cause wetting of the building, furniture etc.

Never touch the internal parts of the controller. Do not remove the front panel. Some parts inside are dangerous to touch, and a machine trouble may happen.

Never expose little children, plants or animals directly to

the air flow. Adverse influence to little children, animals and plants may result.

Do not allow a child to mount on the outdoor unit or avoid placing any object on it. Falling or tumbling may result in injury.

Do not operate the air conditioner when using a room fumigation - type insecticide. Failure to observe could cause the chemicals to become deposited in the unit, which could endanger the health of those who are hypersensitive to chemicals.

Do not place appliances which produce open fire in places exposed to the air flow from the unit or under the indoor unit. It may cause incomplete combustion or deformation of the

Do not install the air conditioner at any place where flammable gas may leak out. If the gas leaks out and stays around the air conditioner, a fire may break out.

The appliance is not intended for use by young children or infirm persons without supervision.

This appliance can be used by children aged from 8 years and above and persons with reduced physical, sensory or mental capabilities or lack of experience and knowledge if they have been given supervision or instruction concerning use of the appliance in a safe way and understand the hazards involved. Children shall not play with the appliance.Cleaning and user maintenance shall not be made by children without supervision.

This appliance is not intended for use by persons (including children) with reduced physical, sensory or mental capabilities.or lack of experience and knowledge. unless they have been given supervision or instruction concerning use of the appliance by a person responsible for their safety.

Children should be supervised to ensure that they do not play with the appliance.

owner's manual

Solution Symptoms Causes Power failure. Wait for the comeback of power. Power switch is off. Switch on the power. Fuse of power switch may have burned. • Replace. Unit does not start Batteries of remote controller exhausted • Replace the batterises or check the or other problem of controller. controller. Air flowing normally but completely can't cooling Temperature is not set correctly. Set the temperature properly. Be in 3 minutes protection of Wait. compressor. Refrigerant is too little or too much. Check leakage, and rightly recharge Air or no concretingc gas in the refrigerant. refrigerating circuit. Vacuum and recharge refrigerant. Maintenance or change compressor Compressor is malfunction. Units start or stop frequently Voltage is too high or too low. Install manostat. System circuit is blocked. Find reasons and solution. Outdoor unit and indoor unit heat • Clean the heat exchanger exchanger is dirty. Clean the air filter. The air filter is dirty. Eliminate all dirties and make ai Inlet/outlet of indoor/outdoor units smooth. Close doors and windows. blocked. Doors and windows are open Make curtains in order to shelter from Low cooling effect Sunlight directly shine. sunshine. Too much heat resource. Reduce heat source. Outdoor temp. is too high. AC cooling capacity reduces (normal). refrigerant. refrigerant. Dutdoor temperature is lower than 7°C • Use heating device. Doors and windows not completely • Close doors and windows. ow heating effect Check leakage and rightly recharge Leakage of refrigerant or lack of refrigerant.

MANUAL OPERATION TIMER Θ DEF./FAN ALARM \bigcirc Temperature indecator Infrared signal receiver NOTE:DEF indicator(cooling and heating type) or FAN indicator(cooling only type) Display panel Fig. 2-4 NOTE:DEF indicator(cooling and heating type) Infrared signal receiver or FAN indicator(cooling only type) Display panel Fig. 2-5 NOTE:DEF indicator(cooling and heating type) or FAN indicator(cooling only type) Infrared signal receiver OPERATION TIMER DEF./FAN ALARM Display panel Fig. 2-6 PRE-DEF indicator(cooling and heating Infrared signal receiver or fan only indicator(cooling only type) Operation lamp Temporary buttor MANUAL Timer indicator Alarm indicator Temperature indecator Display panel Fig. 2-7 For inverter type, this switch is used for after-sales service 3 Optimum performance will be achieved within these purpose only, the user should not push it.

Symptoms	Causes	Solution
The fan speed can not be	 Check whether the MODE indicated on the display is "AUTO" 	When the automatic mode is selected, the air conditioner will automatically change the fan speed.
changed.	 Check whether the MODE indicated on the display is "DRY" 	When dry operation is selected, the air conditioner automatically change the fan speed. The fan speed can be selected during "COOL", "FAN ONLY", and "HEAT".
The remote controller signal is not transmitted even when the ON/OFF button is pushed.	• Check whether the batteries in the remote controller are exhausted.	The power supply is off.
The TEMP. indicator does not come on.	 Check whether the MODE indicated on the display is FAN ONLY 	The temperature cannot be set during FAN mode.
The indication on the display disappears after a lapse of time.	• Check whether the timer operation has come to an end when the TIMER OFF is indicated on the display.	The air conditioner operation will stop up to the set time.
The TIMER ON indicator goes off after a lapse of certain time.	• Check whether the timer operation is started when the TIMER ON is indicated on the display.	Up to the set time, the air conditioner will automatically start and the appropriate indicator will go off.
No receiving tone sounds from the indoor unit even when the ON/OFF button is pressed.	• Check whether the signal transmitter of the remote controller is properly directed to the infrared signal receiver of the indoor unit when the ON/OFF button is pressed.	Directly transmit the signal transmitter of the remote controller to the infrared signal receiver of the indoor unit, and then repeatly push the ON/OFF button twice.

For fixed-frequency type, this function is used to operate the unit temporarily in case you misplace the remote controller or its batteries are exhausted. Two modes including FORCED AUTO and FORCED COOL can be selected through the TEMPORARY BUTTON on the air-in grill control box of the indoor unit. Once you push this button, the air conditioner will run in such order: FORCED AUTO, FORCED COOL, OFF,

and back to FORCED AUTO. FORCED AUTO

The OPERATION lamp is lit, and the air conditioner will run under FORCED AUTO mode. The remote controller operation is enabled to operate according to the received signal.

2 FORCED COOL The OPERATION lamp flashes, the air conditioner will turn to FORCED AUTO after it is enforced to cool with a wind speed of HIGH for 30 minutes. The remote controller operation is disabled

The OPERATION lamp goes off. The air conditioner is OFF while the remote controller operation is enabled.

NOTE

This manual does not include Remote Controller Operations, see the << Remote Controller Owner's manual>> packed with the unit for details.

3. AIR CONDITIONER OPERATIONS AND PERFORMANCE

Use the system in the following temperature for safe and effective operation. The Max operation temperature for the air conditioner.(Cooling/Heating)

	~		 	, -	•••
)	le 3-	-1			

Temperature Mode	Outdoor temperature	Room temperature				
Cooling operation	18°C ~ 43°C / 64 °F~109°F -7°C ~ 43°C / 20 °F~109°F (for the models with low temperature cooling system) 18°C ~ 52°C / 64 °F~126°F	17°C ~ 32°C (62 °F ~ 90°F)				
Heating operation	(for special tropical models) $-7^{\circ}C \sim 24^{\circ}C / 20^{\circ}F \sim 76^{\circ}F$	0°C ~ 30°C / 32 °F~86°F				
Drying operation	18°C ~ 43°C / 64 °F~109°F 18°C ~ 52°C / 64 °F~126°F (for special tropical models)	17°C ~ 32°C (62 °F ~ 90°F)				
ble 3-2(for inverter type air conditioner)						

Temperature Mode	Outdoor temperature	Room temperature
	0°C ~ 50°C / 32 °F~122°F	
ooling operation	-15°C ~ 50°C / 5 °F~122°F (for the models with low temperature cooling system)	17°C ~ 32°C (62 °F ~ 90°F)
eating operation Dling only type without)	-15°C ~ 24°C / 5 °F~76°F	0°C ~ 30°C / 32 °F~86°
rying operation	0°C ~ 50°C / 32 °F~122°F	17°C ~ 32°C (62 °F ~ 90°F)

NOTE

1 If air conditioner is used outside the above conditions, it may cause the unit to function abnormally. 2 The phenomenon is normal that the surface of air conditioning may condense water when the relative larger humidity in room, please close the door and window. operating temperature range.

owner's manua

Three-minute protection feature

A protection feature prevents the air conditioner from being activated for approximately 3 minutes when it restarts immediately after operation.

Power failure

Power failure during operation will stop the unit completely. • The OPERATION lamp on the indoor unit will start

- flashing when power is restored. • To restart operation, push the ON/OFF button on the
- remote controller. • Lighting or a car wireless telephone operating nearby
- may cause the unit to malfunction. Disconnect the unit with the power and then connect the unit with the power again. Push the ON/OFF button on the remote controller to restart operation.
- Refrigerant Leakage Detection(optional): With this new technology, the dipsplay area will appear 'EC' (if applicable) and the LED indication lamps continue flashing
- when the outdoor unit detects refrigerant leakage. Louver Angle Memory Function(optional):
- For some models, the machine is special designed with louver angle memory function. Power failure during operation or pressing the ON/OFF button on the remote controller will stop the unit completely. When the power restores or pressing the ON/OFF button on the remote controller again, the unit restarts automatically with the previous open angle of the horizontal louver by the memory function. So we strongly recommend that the open angle of the horizontal louver should not be set too small, in case the condensed water forms and drops from the horizontal louver. Press the Manual control button and the open angle of the horizontal louver will be restored to the standard

4. HINTS FOR ECONOMICAL OPERATION

The following should be noticed to ensure an economical operation. (Refer to corresponding chapterfor details)

- Adjust the air flow direction properly to avoid winding toward vour body
- Adjust the room temperature properly to get a comfortable situation and to avoid supercooling and superheat.
- In cooling, close the curtains to avoid direct sunlight.
- To keep cool or warm air in the room, never open doors or windows more often than necessary.
- Set the timer for the desired operating time.
- Never put obstructions near the air outlet or the air inlet. Or it 6. MAINTENANCE will cause lower efficiency, even a sudden stop.
- If you don't plan to use the unit for a long time, please disconnect power and remove the batteries from the remote controller. When the power switch is connected, some energy will be consumed, even if the air conditioner isn't in operation. So please disconnect the power to save energy. And please switch the power on 12 hours before you restart the unit to ensure a smooth operation.
- A clogged air filter will reduce cooling or heating efficiency, please clean it once two weeks.

owner's manua


QSDLU-002AEN

. ADJUSTING AIR FLOW DIRECTION

5.1 Adjust the horizontal louver

Press SWING V button, the louver will swing up and down automatically.


Manual Swing Adjust the louver to achieve better cooling/heating effects when cooling /heating.



When cooling Adjust the louver horizontally.




When heating Adjust the louver downwards. (vertically)



5.2 Adjust the Vertical louver

Auto-swing Press SWING H button, the louver will swing left and right automatically.



CAUTION	
Before you clean the air conditioner, be sure the power supply is off.	
Check if the wiring is not broken off or disconnected.	

CALITION

Use a dry cloth to wipe the indoor unit and remote

The design and specifications are subject to change without prior notice for product improvement. Consult with the sales agency or manufacturer for details.