



* Refrigerant leakage contributes to climate change. Refrigerant with lower global warming potential (GWP) would contribute less to global warming than a refrigerant with higher GWP, if leaked to the atmosphere. This appliance contains a refrigerant fluid with a GWP equal to [675]. This means that if 1 kg of this refrigerant fluid would be leaked to the atmosphere, the impact on global warming would be [695] times higher than 1 kg of CO₂, over a period of 100 years. Never try to interfere with the refrigerant circuit yourself or disassemble the product yourself and always ask a professional.

** The annual energy consumption kWh per year, based on standard test results. Actual energy consumption will depend on how the appliance is used and where it is located.

*** The standard rated conditions:

cooling	-outdoor 35° C DB/24° C WB	-indoor 27° C DB/19° C WB
heating	-outdoor 7° C DB/6° C WB	-indoor 20° C DB/15° C WB

If air conditioner is used outside of the above conditions, certain safety protection features may come into operation and cause the unit to function abnormally or damage.