



MŰSZAKI MEGFELELŐSÉGI NYILATKOZAT

A Columbus Klímaértékesítő Kft., mint a gyártó magyarországi hivatalos képviselője, ezúton igazoljuk, hogy a Fisher FSAI-SU-186FE3/FSOAI-SU-186FE3 levegő-levegő hőszivattyú COP megfelelését, azaz hogy a $COPA2/A20 \geq 3$.

Hivatkozva az „Európai Bizottság 206/2012/EU (2012. március 6.) rendelet a 2009/125/EK európai parlamenti és tanácsi irányelvnek a légkondicionáló berendezések és a háztartási ventilátorok környezetbarát tervezésére vonatkozó követelmények tekintetében történő végrehajtásról” szóló rendelete 3. cikk a Környezetbarát tervezési követelmények és időütemezés (2) bekezdés a) pontjára, amely kimondja: a légkondicionáló berendezések – az egycsöves és a kétcsöves légkondicionáló berendezések kivételével – meg kell felelniük az I. melléklet 2. pontjának b) alpontjában, 3. pontjának a), b) és c) alpontjában előírt követelményeknek;

E melléklet, amelyet részletesen a rendelet I. melléklet 3. pontja amely a Termékinformációs követelményeket taglaja, annak 1. táblázata szerinti, a gyártó által megadott táblázat alapja jelen igazolásnak.

A melléklet vonatkozó pontjának megjegyzés rovata szerint: A gyártónak a fenti 1. táblázatban megjelölt adatokat annyiban kell feltüntetnie a termék műszaki dokumentációjában, amennyiben az a funkcionalitás szempontjából lényeges.

Erre való hivatkozással a táblázatot csak a „funkcionalitás szempontjából lényeges” adatokkal adtuk meg.

A COP igazolást a gyártó ezen rendeletben a fent leírt módon adja meg a vonatkozó adatokat:

Information requirements

This information includes the results of calculation of the seasonal energy consumption and efficiency for air conditioner in regards to ErP pursuant to the Commission Regulation(EU) No.206/2012 and No.626/2011. Information to identify the model(s) to which the information relates to:

AIR CONDITIONER

TYPE : SPLIT
WALL-MOUNTED UNIT

Indoor unit(s) : FSAI-SU-186FE3
Outdoor unit : FSOAI-SU-186FE3
Brand : FISHER

Function (indicate if present)				if function includes heating : Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.			
cooling		Y		Average (mandatory)		Y	
heating		Y		Warmer (if designated)		Y	
				Colder (if designated)		Y	
Item	symbol	value	unit	Item	symbol	value	unit
Design load				Seasonal efficiency			
cooling	Pdesignc	5,1	kW	cooling	SEER	6,10	-
heating/Average	Pdesignh	3,8	kW	heating/Average	SCOP/A	4,00	-
heating/Warmer	Pdesignh	5	kW	heating/Warmer	SCOP/W	5,1	-
heating/Colder	Pdesignh	4	kW	heating/Colder	SCOP/C	3,4	-
Declared capacity(*) for cooling, at indoor temperature 27(19)°C and outdoor temperature Tj				Declared energy efficiency ratio(*), at indoor temperature 27(19)°C and outdoor temperature Tj			
Item	symbol	value	unit	Item	symbol	value	unit
Tj = 35°C	Pdc	5,100	kW	Tj = 35°C	EERd	3,30	-
Tj = 30°C	Pdc	3,800	kW	Tj = 30°C	EERd	4,83	-
Tj = 25°C	Pdc	2,450	kW	Tj = 25°C	EERd	7,37	-
Tj = 20°C	Pdc	1,860	kW	Tj = 20°C	EERd	12,01	-
Declared capacity(*) for heating/Average season, at indoor temperature 20°C and outdoor temperature Tj				Declared coefficient of performance(*)/Average season, at indoor temperature 20°C and outdoor temperature Tj			
Item	symbol	value	unit	Item	symbol	value	unit
Tj = -7°C	Pdh	3,370	kW	Tj = -7°C	COPd	2,90	-
Tj = 2°C	Pdh	2,160	kW	Tj = 2°C	COPd	3,94	-
Tj = 7°C	Pdh	1,380	kW	Tj = 7°C	COPd	4,82	-
Tj = 12°C	Pdh	1,250	kW	Tj = 12°C	COPd	6,08	-
Tj = bivalent temperature	Pdh	3,370	kW	Tj = bivalent temperature	COPd	2,90	-
Tj = operating limit	Pdh	4,590	kW	Tj = operating limit	COPd	2,19	-
Declared capacity(*) for heating/Warmer season, at indoor temperature 20°C and outdoor temperature Tj				Declared coefficient of performance(*)/Warmer season, at indoor temperature 20°C and outdoor temperature Tj			
Item	symbol	value	unit	Item	symbol	value	unit
Tj = 2°C	Pdh	5	kW	Tj = 2°C	COPd	2,62	-
Tj = 7°C	Pdh	3,44	kW	Tj = 7°C	COPd	4,7	-
Tj = 12°C	Pdh	1,68	kW	Tj = 12°C	COPd	6,63	-
Tj = bivalent temperature	Pdh	5	kW	Tj = bivalent temperature	COPd	2,62	-
Tj = operating limit	Pdh	5	kW	Tj = operating limit	COPd	2,62	-


SH

Declared capacity(*) for heating/Colder season, at indoor temperature 20°C and outdoor temperature Tj				Declared coefficient of performance(*)/Colder season, at indoor temperature 20°C and outdoor temperature Tj			
Item	symbol	value	unit	Item	symbol	value	unit
Tj = -7°C	Pdh	2,39	kW	Tj = -7°C	COPd	2,98	-
Tj = 2°C	Pdh	1,48	kW	Tj = 2°C	COPd	4,14	-
Tj = 7°C	Pdh	0,99	kW	Tj = 7°C	COPd	4,8	-
Tj = 12°C	Pdh	1,3	kW	Tj = 12°C	COPd	5,73	-
Tj = bivalent temperature	Pdh	3,27	kW	Tj = bivalent temperature	COPd	1,85	-
Tj = operating limit	Pdh	2,99	kW	Tj = operating limit	COPd	1,71	-
Tj = -15°C	Pdh	3,27	kW	Tj = -15°C	COPd	1,85	-
Bivalent temperature				Operating limit temperature			
heating/Average	Tbiv	-7	°C	heating/Average	Tol	-15	°C
heating/Warmer	Tbiv	2	°C	heating/Warmer	Tol	2	°C
heating/Colder	Tbiv	-15	°C	heating/Colder	Tol	-22	°C
Cycling interval capacity				Cycling interval efficiency			
for cooling	Pcycc	x,x	kW	heating/Average	EERcyc	x,x	-
for heating	Pcyh	x,x	kW	heating/Warmer	COPcyc	x,x	-
Degradation co-efficient cooling	Cdc	0,25	-	Degradation co-efficient heating	Cdc	0,25	-
Electric power input in power modes other than 'active mode'				Annual electricity consumption			
off mode	Poff	0,000	kW	cooling	Qce	293	kWh/a
standby mode	Psb	0,005	kW	heating/Average	Qhe	1330	kWh/a
thermostat-off mode	Pto	0,045	kW	heating/Warmer	Qhe	1373	kWh/a
crankcase heater mode	Pck	0	kW	heating/Colder	Qhe	2471	kWh/a
Capacity control(indicate one of the options)				Other items			
Item	symbol	value	unit	Item	symbol	value	unit
fixed		N		Sound power level (indoor/outdoor)	LWA	54/65	dB(A)
staged		N		Global warning potential	GWP	675	kgCO ₂ eq
variable		Y		Rated air flow (indoor/outdoor)	-	820/2600	m ³ /h

tehát $SCOP_A = 4$
azaz a keresett SCOP alapján a berendezés megfelel a követelménynek.

Dátum: 2024. 11.15.

Aláírás:



Név: Katona Zoltán
gépészmérnök
Columbus Klímaértékesítő Kft.
2142 Nagytarcsa Pesti út 15.
Adószám: 13848725-2-13
Bsz.: 11784009-22238612
17.