



MŰSZAKI MEGFELELŐSÉGI NYILATKOZAT

A Columbus Klímaértékesítő Kft., mint a gyártó magyarországi hivatalos képviselője, ezúton igazoljuk, hogy a Fisher FSAI-SU-123AE3/FSOAI-SU-123AE3 levegő-levegő hőszivattyú COP megfelelőségét, azaz hogy a $COPA2/A20 \geq 3$.

Hivatkozva az „Európai Bizottság 206/2012/EU (2012. március 6.) rendelet a 2009/125/EK európai parlamenti és tanácsi irányelvnek a légkondicionáló berendezések és a háztartási ventilátorok környezetbarát tervezésére vonatkozó követelmények tekintetében történő végrehajtásról” szülő rendelete 3. cikk a Környezetbarát tervezési követelmények és időütemezés (2) bekezdés a) pontjára, amely kimondja: a légkondicionáló berendezések – az egycsöves és a kétsöves légkondicionáló berendezések kivételével – meg kell felelniük az I. melléklet 2. pontjának b) alpontjában, 3. pontjának a), b) és c) alpontjában előírt követelményeknek;

E melléklet, amelyet részletesen a rendelet I. melléklet 3. pontja amely a Termékinformációs követelményeket taglaja, annak 1. táblázata szerinti, a gyártó által megadott táblázat alapja jelen igazolásnak.

A melléklet vonatkozó pontjának megjegyzés rovata szerint: A gyártónak a fenti 1. táblázatban megjelölt adatokat annyiban kell feltüntetnie a termék műszaki dokumentációjában, amennyiben az a funkcionalitás szempontjából lényeges.

Erre való hivatkozással a táblázatot csak a „funktionalitás szempontjából lényeges” adatokkal adtuk meg.

A COP igazolást a gyártó ezen rendeletben a fent leírt módon adja meg a vonatkozó adatokat:

Information requirements

This information includes the results of calculation of the seasonal energy consumption and efficiency for air conditioner in regards to ErP pursuant to the Commission Regulation(EU) No.206/2012 and No.626/2011. Information to identify the model(s) to which the information relates to:

AIR CONDITIONER
 TYPE : Split
 WALL-MOUNTED
 Indoor unit(s) : FSAI-SU-123AE3
 Outdoor unit : FSOAI-SU-123AE3
 Brand : FISHER

Function (indicate if present)				if function includes heating : Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.			
cooling	Y			Average (mandatory)		Y	
heating	Y			Warmer (if designated)		N	
				Colder (if designated)		N	
Item	symbol	value	unit	Item	symbol	value	unit
Design load				Seasonal efficiency			
cooling	Pdesignc	3,5	kW	cooling	SEER	6,1	-
heating/Average	Pdesignh	2,3	kW	heating/Average	SCOP/A	4,0	-
heating/Warmer	Pdesignh	x,x	kW	heating/Warmer	SCOP/W	x,x	-
heating/Colder	Pdesignh	x,x	kW	heating/Colder	SCOP/C	x,x	-
Declared capacity(*) for cooling, at indoor temperature 27(19)°C and outdoor temperature Tj				Declared energy efficiency ratio(*), at indoor temperature 27(19)°C and outdoor temperature Tj			
Item	symbol	value	unit	Item	symbol	value	unit
Tj = 35°C	Pdc	3,500	kW	Tj = 35°C	EERd	2,950	-
Tj = 30°C	Pdc	2,632	kW	Tj = 30°C	EERd	4,500	-
Tj = 25°C	Pdc	1,677	kW	Tj = 25°C	EERd	7,400	-
Tj = 20°C	Pdc	1,008	kW	Tj = 20°C	EERd	11,400	-
Declared capacity(*) for heating/Average season, at indoor temperature 20°C and outdoor temperature Tj				Declared coefficient of performance(*)/Average season, at indoor temperature 20°C and outdoor temperature Tj			
Item	symbol	value	unit	Item	symbol	value	unit
Tj = -7°C	Pdh	2,030	kW	Tj = -7°C	COPd	2,900	-
Tj = 2°C	Pdh	1,325	kW	Tj = 2°C	COPd	4,150	-
Tj = 7°C	Pdh	0,843	kW	Tj = 7°C	COPd	4,523	-
Tj = 12°C	Pdh	0,696	kW	Tj = 12°C	COPd	5,200	-
Tj = bivalent temperature	Pdh	2,030	kW	Tj = bivalent temperature	COPd	2,900	-
Tj = operating limit	Pdh	2,295	kW	Tj = operating limit	COPd	2,649	-
Declared capacity(*) for heating/Warmer season, at indoor temperature 20°C and outdoor temperature Tj				Declared coefficient of performance(*)/Warmer season, at indoor temperature 20°C and outdoor temperature Tj			
Item	symbol	value	unit	Item	symbol	value	unit
Tj = 2°C	Pdh	x,x	kW	Tj = 2°C	COPd	x,x	-
Tj = 7°C	Pdh	x,x	kW	Tj = 7°C	COPd	x,x	-
Tj = 12°C	Pdh	x,x	kW	Tj = 12°C	COPd	x,x	-
Tj = bivalent temperature	Pdh	x,x	kW	Tj = bivalent temperature	COPd	x,x	-
Tj = operating limit	Pdh	x,x	kW	Tj = operating limit	COPd	x,x	-

Item	symbol	value	unit	Item	symbol	value	unit
Tj = -7°C	Pdh	x,x	kW	Tj = -7°C	COPd	x,x	-
Tj = 2°C	Pdh	x,x	kW	Tj = 2°C	COPd	x,x	-
Tj = 7°C	Pdh	x,x	kW	Tj = 7°C	COPd	x,x	-
Tj = 12°C	Pdh	x,x	kW	Tj = 12°C	COPd	x,x	-
Tj = bivalent temperature	Pdh	x,x	kW	Tj = bivalent temperature	COPd	x,x	-
Tj = operating limit	Pdh	x,x	kW	Tj = operating limit	COPd	x,x	-
Tj = -20°C	Pdh	x,x	kW	Tj = -20°C	COPd	x,x	-
Bivalent temperature				Operating limit temperature			
heating/Average	Tbiv	-7	°C	heating/Average	Tol	-10	°C
heating/Warmer	Tbiv	x	°C	heating/Warmer	Tol	x	°C
heating/Colder	Tbiv	x	°C	heating/Colder	Tol	x	°C
Cycling interval capacity				Cycling interval efficiency			
for cooling	Pcycc	x,x	kW	heating/Average	EERcyc	x,x	-
for heating	Pcyh	x,x	kW	heating/Warmer	COPcyc	x,x	-
Degradation co-efficient cooling	Cdc	0,25	-	Degradation co-efficient heating	Cdc	0,25	-
Electric power input in power modes other than 'active mode'				Annual electricity consumption			
off mode	Poff	0,001	kW	cooling	Q _{CE}	201	kWh/a
standby mode	Psb	0,001	kW	heating/Average	Q _{he}	805	kWh/a
thermostat-off mode	Pto	0,026	kW	heating/Warmer	Q _{he}	x	kWh/a
crankcase heater mode	Pck	0	kW	heating/Colder	Q _{he}	x	kWh/a
Capacity control(indicate one of the options)				Other items			
Item	symbol	value	unit	Item	symbol	value	unit
fixed		Y/N		Sound power level (indoor/outdoor)	LWA	53/65	dB(A)
staged		Y/N		Global warming potential	GWP	675	kgCO ₂ eq
variable		Y		Rated air flow (indoor/outdoor)	-	x	m ³ /h

tehát COP_{A2/A20} = 4,15

azaz a keresett COP alapján a berendezés megfelel a követelménynek.

Dátum: 2018. június 6.

Aláírás:



Név: Katona Zoltán
gépészmérnök

Columbus Klímaértékesítő Kft.
2142 Nagytarcsa, Pesti út 15.
Adószám: 13848725-2-13
Bsz.: 14100000-22078949-01000008
10.